

Declaration of Conformity

150A Restrained Receptacle

Serial Number:	81509-01	Date:	20/05/2025
Catalogue Number:	AG114B		
Final Inspection Details			
Receptacle base FLP flatness & min length (12.5)			Pass
Diametral clearance between Casting bore and Interior (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Interior bore and Insulator (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Main Pin (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Pilot Pin (≤ 0.5) (min length 25.0)			Pass
Plug entry diameter (71.7 / 71.8) (min length 25.0)			Pass
Correct label details			Checked Ok

CMI Electrical Products, a division of CMI Operations P/L and manufacturer of Minto Industrial Products conforms to ISO9001 and is verified through an external accredited certification body.

The Minto Industrial Product Range is certified to comply with AS/NZS 1299 and AS/NZS 1300. This product is therefore compatible with other products that are also designed & certified to these standards.

The 150A range of Restrained Receptacle certification details are:

- IECEx TSA 14.0033X Issue 4; Dated 2023-09-22
- ANZEx 14.3016 Issue 4, Dated 2023-09-22

The relevant Certificates of Conformity, Drawings and Fitting-Maintenance Instructions for this product can be downloaded from the Certificates section of the CMI Website. <https://cmielectrical.com.au/certifications> (Requires Registration)

The manufacturing system is such that all raw materials are machined by approved subcontractors and supplied to CMI as conforming product. Minto Industrial Products undertakes routine batch tests on components prior to placing into stock. All components that include flamepaths have individual dimensional checks undertaken. Electrical testing of interior insulation materials is conducted on all individual components

A unique serial number is placed on these products to allow for traceability. The product described above has been checked and was compliant at the time of dispatch from CMI Electrical Products. It is the responsibility of the person installing this product to confirm that no damage has occurred during transit or installation. The user must ensure that the item is fit for purpose, compliant and has been installed in accordance with CMI's installation documentation and the relevant Australian standards.

Contact CMI directly if technical information or assistance is required for this product.

[Email at: support@cmielectrical.com.au](mailto:support@cmielectrical.com.au)

Item Quality Certified By:	CMI Production Supervision
-----------------------------------	-----------------------------------

This document is traceable to CMI internal quality documents

Dec AG1 Product Declaration of Conformity Statement (2024.01.15)



minto industrial products



Afex Cables



XLPE cables



HARTLAND CABLES



Declaration of Conformity

150A Restrained Receptacle

Serial Number:	81509-02	Date:	20/05/2025
Catalogue Number:	AG114B		
Final Inspection Details			
Receptacle base FLP flatness & min length (12.5)			Pass
Diametral clearance between Casting bore and Interior (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Interior bore and Insulator (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Main Pin (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Pilot Pin (≤ 0.5) (min length 25.0)			Pass
Plug entry diameter (71.7 / 71.8) (min length 25.0)			Pass
Correct label details			Checked Ok

CMI Electrical Products, a division of CMI Operations P/L and manufacturer of Minto Industrial Products conforms to ISO9001 and is verified through an external accredited certification body.

The Minto Industrial Product Range is certified to comply with AS/NZS 1299 and AS/NZS 1300. This product is therefore compatible with other products that are also designed & certified to these standards.

The 150A range of Restrained Receptacle certification details are:

- IECEx TSA 14.0033X Issue 4; Dated 2023-09-22
- ANZEx 14.3016 Issue 4, Dated 2023-09-22

The relevant Certificates of Conformity, Drawings and Fitting-Maintenance Instructions for this product can be downloaded from the Certificates section of the CMI Website. <https://cmielectrical.com.au/certifications> (Requires Registration)

The manufacturing system is such that all raw materials are machined by approved subcontractors and supplied to CMI as conforming product. Minto Industrial Products undertakes routine batch tests on components prior to placing into stock. All components that include flamepaths have individual dimensional checks undertaken. Electrical testing of interior insulation materials is conducted on all individual components

A unique serial number is placed on these products to allow for traceability. The product described above has been checked and was compliant at the time of dispatch from CMI Electrical Products. It is the responsibility of the person installing this product to confirm that no damage has occurred during transit or installation. The user must ensure that the item is fit for purpose, compliant and has been installed in accordance with CMI's installation documentation and the relevant Australian standards.

Contact CMI directly if technical information or assistance is required for this product.

[Email at: support@cmielectrical.com.au](mailto:support@cmielectrical.com.au)

Item Quality Certified By:	CMI Production Supervision
-----------------------------------	-----------------------------------

This document is traceable to CMI internal quality documents

Dec AG1 Product Declaration of Conformity Statement (2024.01.15)

Declaration of Conformity

150A Restrained Receptacle

Serial Number:	81509-03	Date:	20/05/2025
Catalogue Number:	AG114B		
Final Inspection Details			
Receptacle base FLP flatness & min length (12.5)			Pass
Diametral clearance between Casting bore and Interior (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Interior bore and Insulator (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Main Pin (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Pilot Pin (≤ 0.5) (min length 25.0)			Pass
Plug entry diameter (71.7 / 71.8) (min length 25.0)			Pass
Correct label details			Checked Ok

CMI Electrical Products, a division of CMI Operations P/L and manufacturer of Minto Industrial Products conforms to ISO9001 and is verified through an external accredited certification body.

The Minto Industrial Product Range is certified to comply with AS/NZS 1299 and AS/NZS 1300. This product is therefore compatible with other products that are also designed & certified to these standards.

The 150A range of Restrained Receptacle certification details are:

- IECEx TSA 14.0033X Issue 4; Dated 2023-09-22
- ANZEx 14.3016 Issue 4, Dated 2023-09-22

The relevant Certificates of Conformity, Drawings and Fitting-Maintenance Instructions for this product can be downloaded from the Certificates section of the CMI Website. <https://cmielectrical.com.au/certifications> (Requires Registration)

The manufacturing system is such that all raw materials are machined by approved subcontractors and supplied to CMI as conforming product. Minto Industrial Products undertakes routine batch tests on components prior to placing into stock. All components that include flamepaths have individual dimensional checks undertaken. Electrical testing of interior insulation materials is conducted on all individual components

A unique serial number is placed on these products to allow for traceability. The product described above has been checked and was compliant at the time of dispatch from CMI Electrical Products. It is the responsibility of the person installing this product to confirm that no damage has occurred during transit or installation. The user must ensure that the item is fit for purpose, compliant and has been installed in accordance with CMI's installation documentation and the relevant Australian standards.

Contact CMI directly if technical information or assistance is required for this product.

[Email at: support@cmielectrical.com.au](mailto:support@cmielectrical.com.au)

Item Quality Certified By:	CMI Production Supervision
-----------------------------------	-----------------------------------

This document is traceable to CMI internal quality documents

Dec AG1 Product Declaration of Conformity Statement (2024.01.15)



minto industrial products



Afex Cables



XLPE cables



HARTLAND CABLES



Declaration of Conformity

150A Restrained Receptacle

Serial Number:	81509-04	Date:	20/05/2025
Catalogue Number:	AG114B		
Final Inspection Details			
Receptacle base FLP flatness & min length (12.5)			Pass
Diametral clearance between Casting bore and Interior (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Interior bore and Insulator (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Main Pin (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Pilot Pin (≤ 0.5) (min length 25.0)			Pass
Plug entry diameter (71.7 / 71.8) (min length 25.0)			Pass
Correct label details			Checked Ok

CMI Electrical Products, a division of CMI Operations P/L and manufacturer of Minto Industrial Products conforms to ISO9001 and is verified through an external accredited certification body.

The Minto Industrial Product Range is certified to comply with AS/NZS 1299 and AS/NZS 1300. This product is therefore compatible with other products that are also designed & certified to these standards.

The 150A range of Restrained Receptacle certification details are:

- IECEx TSA 14.0033X Issue 4; Dated 2023-09-22
- ANZEx 14.3016 Issue 4, Dated 2023-09-22

The relevant Certificates of Conformity, Drawings and Fitting-Maintenance Instructions for this product can be downloaded from the Certificates section of the CMI Website. <https://cmielectrical.com.au/certifications> (Requires Registration)

The manufacturing system is such that all raw materials are machined by approved subcontractors and supplied to CMI as conforming product. Minto Industrial Products undertakes routine batch tests on components prior to placing into stock. All components that include flamepaths have individual dimensional checks undertaken. Electrical testing of interior insulation materials is conducted on all individual components

A unique serial number is placed on these products to allow for traceability. The product described above has been checked and was compliant at the time of dispatch from CMI Electrical Products. It is the responsibility of the person installing this product to confirm that no damage has occurred during transit or installation. The user must ensure that the item is fit for purpose, compliant and has been installed in accordance with CMI's installation documentation and the relevant Australian standards.

Contact CMI directly if technical information or assistance is required for this product.

[Email at: support@cmielectrical.com.au](mailto:support@cmielectrical.com.au)

Item Quality Certified By:	CMI Production Supervision
-----------------------------------	-----------------------------------

This document is traceable to CMI internal quality documents

Dec AG1 Product Declaration of Conformity Statement (2024.01.15)



minto industrial products



Afex Cables



XLPE cables



HARTLAND CABLES



- **Sydney** F3 3-29 Birnie Avenue Lidcombe NSW 2141
Telephone: (02) 9807 6155 Facsimile: (02) 9808 2033
- **Melbourne** 3-5 Dissik Street Cheltenham VIC 3192
Telephone: (03) 9532 1233 Facsimile: (03) 9553 3502
- **Perth** 36 Division Street Welshpool WA 6106
Telephone: (08) 9358 1788 Facsimile (08) 9358 1733

- **Brisbane** 32 Duntroon St Brendale QLD 4500
Postal Address: PO Box 642 Virginia QLD 4014
Telephone: (07) 3863 0749 Facsimile (07) 3863 0795
- **Rockhampton** Shop 3, 76 Hollingsworth Street North
Rockhampton QLD 4701
Postal Address PO Box 1124 North Rockhampton QLD 4701
Telephone: (07) 4921 0978 Facsimile (07) 4921 0981

Declaration of Conformity

150A Restrained Receptacle

Serial Number:	81509-05	Date:	20/05/2025
Catalogue Number:	AG114B		
Final Inspection Details			
Receptacle base FLP flatness & min length (12.5)			Pass
Diametral clearance between Casting bore and Interior (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Interior bore and Insulator (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Main Pin (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Pilot Pin (≤ 0.5) (min length 25.0)			Pass
Plug entry diameter (71.7 / 71.8) (min length 25.0)			Pass
Correct label details			Checked Ok

CMI Electrical Products, a division of CMI Operations P/L and manufacturer of Minto Industrial Products conforms to ISO9001 and is verified through an external accredited certification body.

The Minto Industrial Product Range is certified to comply with AS/NZS 1299 and AS/NZS 1300. This product is therefore compatible with other products that are also designed & certified to these standards.

The 150A range of Restrained Receptacle certification details are:

- IECEx TSA 14.0033X Issue 4; Dated 2023-09-22
- ANZEx 14.3016 Issue 4, Dated 2023-09-22

The relevant Certificates of Conformity, Drawings and Fitting-Maintenance Instructions for this product can be downloaded from the Certificates section of the CMI Website. <https://cmielectrical.com.au/certifications> (Requires Registration)

The manufacturing system is such that all raw materials are machined by approved subcontractors and supplied to CMI as conforming product. Minto Industrial Products undertakes routine batch tests on components prior to placing into stock. All components that include flamepaths have individual dimensional checks undertaken. Electrical testing of interior insulation materials is conducted on all individual components

A unique serial number is placed on these products to allow for traceability. The product described above has been checked and was compliant at the time of dispatch from CMI Electrical Products. It is the responsibility of the person installing this product to confirm that no damage has occurred during transit or installation. The user must ensure that the item is fit for purpose, compliant and has been installed in accordance with CMI's installation documentation and the relevant Australian standards.

Contact CMI directly if technical information or assistance is required for this product.

[Email at: support@cmielectrical.com.au](mailto:support@cmielectrical.com.au)

Item Quality Certified By:	CMI Production Supervision
-----------------------------------	-----------------------------------

This document is traceable to CMI internal quality documents

Dec AG1 Product Declaration of Conformity Statement (2024.01.15)



minto industrial products



Afex Cables



XLPE cables



HARTLAND CABLES



Declaration of Conformity

150A Restrained Receptacle

Serial Number:	81509-06	Date:	20/05/2025
Catalogue Number:	AG114B		
Final Inspection Details			
Receptacle base FLP flatness & min length (12.5)			Pass
Diametral clearance between Casting bore and Interior (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Interior bore and Insulator (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Main Pin (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Pilot Pin (≤ 0.5) (min length 25.0)			Pass
Plug entry diameter (71.7 / 71.8) (min length 25.0)			Pass
Correct label details			Checked Ok

CMI Electrical Products, a division of CMI Operations P/L and manufacturer of Minto Industrial Products conforms to ISO9001 and is verified through an external accredited certification body.

The Minto Industrial Product Range is certified to comply with AS/NZS 1299 and AS/NZS 1300. This product is therefore compatible with other products that are also designed & certified to these standards.

The 150A range of Restrained Receptacle certification details are:

- IECEx TSA 14.0033X Issue 4; Dated 2023-09-22
- ANZEx 14.3016 Issue 4, Dated 2023-09-22

The relevant Certificates of Conformity, Drawings and Fitting-Maintenance Instructions for this product can be downloaded from the Certificates section of the CMI Website. <https://cmielectrical.com.au/certifications> (Requires Registration)

The manufacturing system is such that all raw materials are machined by approved subcontractors and supplied to CMI as conforming product. Minto Industrial Products undertakes routine batch tests on components prior to placing into stock. All components that include flamepaths have individual dimensional checks undertaken. Electrical testing of interior insulation materials is conducted on all individual components

A unique serial number is placed on these products to allow for traceability. The product described above has been checked and was compliant at the time of dispatch from CMI Electrical Products. It is the responsibility of the person installing this product to confirm that no damage has occurred during transit or installation. The user must ensure that the item is fit for purpose, compliant and has been installed in accordance with CMI's installation documentation and the relevant Australian standards.

Contact CMI directly if technical information or assistance is required for this product.

[Email at: support@cmielectrical.com.au](mailto:support@cmielectrical.com.au)

Item Quality Certified By:	CMI Production Supervision
-----------------------------------	-----------------------------------

This document is traceable to CMI internal quality documents

Dec AG1 Product Declaration of Conformity Statement (2024.01.15)



minto industrial products



Afex Cables



XLPE cables



HARTLAND CABLES



Declaration of Conformity

150A Restrained Receptacle

Serial Number:	81509-07	Date:	20/05/2025
Catalogue Number:	AG114B		
Final Inspection Details			
Receptacle base FLP flatness & min length (12.5)			Pass
Diametral clearance between Casting bore and Interior (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Interior bore and Insulator (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Main Pin (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Pilot Pin (≤ 0.5) (min length 25.0)			Pass
Plug entry diameter (71.7 / 71.8) (min length 25.0)			Pass
Correct label details			Checked Ok

CMI Electrical Products, a division of CMI Operations P/L and manufacturer of Minto Industrial Products conforms to ISO9001 and is verified through an external accredited certification body.

The Minto Industrial Product Range is certified to comply with AS/NZS 1299 and AS/NZS 1300. This product is therefore compatible with other products that are also designed & certified to these standards.

The 150A range of Restrained Receptacle certification details are:

- IECEx TSA 14.0033X Issue 4; Dated 2023-09-22
- ANZEx 14.3016 Issue 4, Dated 2023-09-22

The relevant Certificates of Conformity, Drawings and Fitting-Maintenance Instructions for this product can be downloaded from the Certificates section of the CMI Website. <https://cmielectrical.com.au/certifications> (Requires Registration)

The manufacturing system is such that all raw materials are machined by approved subcontractors and supplied to CMI as conforming product. Minto Industrial Products undertakes routine batch tests on components prior to placing into stock. All components that include flamepaths have individual dimensional checks undertaken. Electrical testing of interior insulation materials is conducted on all individual components

A unique serial number is placed on these products to allow for traceability. The product described above has been checked and was compliant at the time of dispatch from CMI Electrical Products. It is the responsibility of the person installing this product to confirm that no damage has occurred during transit or installation. The user must ensure that the item is fit for purpose, compliant and has been installed in accordance with CMI's installation documentation and the relevant Australian standards.

Contact CMI directly if technical information or assistance is required for this product.

[Email at: support@cmielectrical.com.au](mailto:support@cmielectrical.com.au)

Item Quality Certified By:	CMI Production Supervision
-----------------------------------	-----------------------------------

This document is traceable to CMI internal quality documents

Dec AG1 Product Declaration of Conformity Statement (2024.01.15)



minto industrial products



Afex Cables



XLPE cables



HARTLAND CABLES



Global-Mark.com.au®

Declaration of Conformity

150A Restrained Receptacle

Serial Number:	81509-08	Date:	20/05/2025
Catalogue Number:	AG114B		
Final Inspection Details			
Receptacle base FLP flatness & min length (12.5)			Pass
Diametral clearance between Casting bore and Interior (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Interior bore and Insulator (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Main Pin (≤ 0.5) (min length 25.0)			Pass
Diametral clearance between Insulator bore and Pilot Pin (≤ 0.5) (min length 25.0)			Pass
Plug entry diameter (71.7 / 71.8) (min length 25.0)			Pass
Correct label details			Checked Ok

CMI Electrical Products, a division of CMI Operations P/L and manufacturer of Minto Industrial Products conforms to ISO9001 and is verified through an external accredited certification body.

The Minto Industrial Product Range is certified to comply with AS/NZS 1299 and AS/NZS 1300. This product is therefore compatible with other products that are also designed & certified to these standards.

The 150A range of Restrained Receptacle certification details are:

- IECEx TSA 14.0033X Issue 4; Dated 2023-09-22
- ANZEx 14.3016 Issue 4, Dated 2023-09-22

The relevant Certificates of Conformity, Drawings and Fitting-Maintenance Instructions for this product can be downloaded from the Certificates section of the CMI Website. <https://cmielectrical.com.au/certifications> (Requires Registration)

The manufacturing system is such that all raw materials are machined by approved subcontractors and supplied to CMI as conforming product. Minto Industrial Products undertakes routine batch tests on components prior to placing into stock. All components that include flamepaths have individual dimensional checks undertaken. Electrical testing of interior insulation materials is conducted on all individual components

A unique serial number is placed on these products to allow for traceability. The product described above has been checked and was compliant at the time of dispatch from CMI Electrical Products. It is the responsibility of the person installing this product to confirm that no damage has occurred during transit or installation. The user must ensure that the item is fit for purpose, compliant and has been installed in accordance with CMI's installation documentation and the relevant Australian standards.

Contact CMI directly if technical information or assistance is required for this product.

[Email at: support@cmielectrical.com.au](mailto:support@cmielectrical.com.au)

Item Quality Certified By:	CMI Production Supervision
-----------------------------------	-----------------------------------

This document is traceable to CMI internal quality documents

Dec AG1 Product Declaration of Conformity Statement (2024.01.15)



minto industrial products



Afex Cables



XLPE cables



HARTLAND CABLES

